

CITY OF SONORA
Public Water Supply ID: TX2180001

Consumer Confidence Report

2025 CCR

Annual Drinking Water Quality Report

CITY OF SONORA

Sutton County

Public Water System ID: TX2180001

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. (Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al teléfono (325) 387-2558).

For more information regarding this report, contact:

Name: Charlotte Mc Elwain

Phone: 325.387.2558

Public Inquiries:

If you have any questions about this report or any other issue concerning your water utility, please contact Charlotte Mc Elwain at (325) 683-4105. We want you to be informed about our water quality. If you want to learn more, please attend any of our regularly scheduled city council meetings. [§290.272\(g\)\(2\)](#)

Day: 3rd Monday of each month Time: 5:00 p.m. Location: City Hall 201 E. Main Street, Sonora, TX 76950

Sources of Drinking Water

CITY OF SONORA is Ground water. Our water comes from the Gulf Coast Aquifer system, from Chicot, Evangeline, and Jasper subunit Aquifers.

Our water source(s) and source water assessment information are listed below:

Source Name	Type of Water	Report Status	Location	
1 - CITY HILL	CITY HILL	Ground water	Yes	https://gisweb.tceq.texas.gov/swat/2180001
1 - I-10 / TX 467 LOOP	LOVES EAST	Ground water	Yes	https://gisweb.tceq.texas.gov/swat/2180001
2 - CITY HILL	CITY HILL	Ground water	Yes	https://gisweb.tceq.texas.gov/swat/2180001
2 - I-10 / TX 467 LOOP	LOVES WEST	Ground water	Yes	https://gisweb.tceq.texas.gov/swat/2180001
3 - CITY HILL	CITY HILL	Ground water	Yes	https://gisweb.tceq.texas.gov/swat/2180001
6 - MAIN ST	MAIN ST	Ground water	Yes	https://gisweb.tceq.texas.gov/swat/2180001

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least some small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office at (325) 683-4105.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. CITY OF SONORA is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact CITY OF SONORA at 325-387-2558. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Chlorine	2025	1.31	Mg/l	0.50 – 2.41	4/4

Additional Health Information for Chlorine §290.272(g)(2)

Chlorine is intentionally added and carefully regulated by the U.S. Environmental Protection Agency (EPA) under the Safe Drinking Water Act (SDWA) to safeguard public health. These regulations specifically include balancing risks associated with waterborne disease protection and exposure to very low levels of disinfection byproducts (DBPs). Chlorine is used to disinfect the drinking water because it controls bacteria growth like E. coli and Giardia. If present, elevated levels of chlorine can have adverse health effects such as eyes and nose, and skin irritations.

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Microbiological	Result	MCL	MCLG	Typical Source
COLIFORM (TCR)	In the month of August, 1 sample(s) returned as positive	Treatment Technique Trigger	0	Naturally present in the environment

Additional Required Health Effects Language:

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2023	0.2617	0.0193 - 0.8177	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2023	1.2	0 - 32.2	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits

Additional Required Health Effects Language:

Infants and children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4761). You can find the water system Lead Service Line Inventory on our webpage at https://sonoratexas.gov/wp-content/uploads/2025/04/TX2180001_LSLI_Export_2025-03-17.xlsx

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	213 HILLTOP ST, SONORA	2025	11	11.3	ppb	60	0	By-product of drinking water disinfection
TTHM	450 2R PVT ROAD 3538, SONORA	2025	9	8.6	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	8/4/2025	0.265	0.162 - 0.265	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DIBROMOCHLOROMETHANE	8/4/2025	6.6	0 - 6.6	UG/L	0	0.06	
FLUORIDE	8/4/2025	0.91	0.91	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL	2/19/2025	0.0016	0.0014 - 0.0016	MG/L	0	0.1	Erosion of natural deposits; Industrial Activities, and leaching from metal surfaces
NITRATE	2/19/2025	1.82	1.66 - 1.82	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	5/19/2021	1.79	1.79	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED URANIUM	8/4/2025	2.1	2.1	µg/L	30	0	Erosion of natural deposits
GROSS ALPHA, EXCL. RADON & U	8/4/2025	3	3	pCi/L	15	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U	8/4/2025	4.5	4.5	pCi/L	0	0	Erosion of natural deposits

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
7/1/2025	CONSUMER CONFIDENCE RULE	CCR REPORT	Failed to deliver Consumer Confidence Report to the state or consumers on time

Additional Information:

Lead and Copper Rule

The Lead and Copper Rule requires community water systems to prepare and provide a water service line inventory that has the pipe material of the water service line serving that connection. City of Sonora has complied with this requirement, and the Water System Lead Service Line Inventory can be found on our website. https://sonoratexas.gov/wp-content/uploads/2025/04/TX2180001_LSLI_Export_2025-03-17.xlsx

We have posted informational public notice with **health effects of lead** for those customers with affected service lines on our website at: <https://sonoratexas.gov/wp-content/uploads/2025/04/known-or-potential-lsl-pn-english.pdf>

Water Loss for 2025

In the water loss audit submitted to the Texas Water Development Board for the time period of January- December 2025, our system lost an estimated 10,437,080 gallons of water. If you have any questions about the water loss audit please call City of Sonora, (325) 387-2558.

